



1 FIRST FLOOR ELECTRICAL PLAN
14-E21 SCALE: 1/8" = 1'-0"

SHEET NOTES

- ① (E) PANEL 343A3A27A19A = 100A BUS, 208Y/120V, 3ø, 4W; KAIC = 10AMP. ADDED (N) LOAD = 153 WATTS.

DESIGN CRITERIA:

71. PROVIDE ILLUMINATED EXIT SIGNS AS REQUIRED TO PROPERLY IDENTIFY EXIT PATHWAYS.
188. PROVIDE ADEQUATE EMERGENCY LIGHTING FOR THE EXIT WAYS.

ESS ARCHITECTS
448 Eighth Street
San Francisco, CA 94103
415 332-0220
415 332-1565 Fax

CONSULTANT
MAZZETTI & ASSOCIATES, INC.
Consulting Mechanical & Electrical Engineers
1000 DIVISadero STREET - SAN FRANCISCO, CA 94103-4671
TELEPHONE (415) 864-5888 FAX (415) 864-4353
F 401-285

REVISIONS	no.	date	description
90% TITLE II	9/28/94		
100% TITLE II	11/7/94		
FINAL TITLE II	2/13/95		
REISSUE FINAL TITLE II	3/30/95		
AS BUILT	7/25/97		

JOB TITLE

FIRE AND SAFETY SYSTEMS UPGRADE
PHASE I
LAWRENCE BERKELEY LABORATORY, UNIVERSITY OF CALIFORNIA
BERKELEY, CALIFORNIA

KEY PLAN



ESS ARCHITECTS JOB #: 9292
LBL SC#: 728
LBL FILE DRAWING:
ACAD FILE NAME:
LBL#L
DWG. 3N14E002E
PROJ # 120257

SHEET TITLE:
BLDG. 14
FIRST FLOOR
ELECTRICAL PLAN
SCALE: 1/8"=1'-0"
DATE: 2/13/95
SHEET:
14-E2.1E